

20 Roy Street. Radon Report 5/30/08

From: Steve Mangelkian [sman2@comcast.net]
Sent: Friday, May 30, 2008 8:48 PM
To: 'Richard Berman'
Subject: 20 Roy radon

Here is the attached radon test report. The result was 1.25 Pico Curies per liter. This is an acceptable level according to EPA standards. The EPA recommends mitigation for any reading over 4.0. For more information you can go to www.EPA.Gov or contact the State of NH Department of Environmental Services

Please contact me any time if I can be of any assistance.

Regards Steve

Stephan Mangelkian
National Property Inspection

ph. 603.816.1014 fax 603.816.0171
e-mail sman2@comcast.net
web: www.npiweb.com/mangelkian